



# Certificate of Compliance

**Certificate:** 2700364 **Master Contract:** 178267 (078713\_0\_000)

**Project:** 70163398 **Date Issued:** 2018-03-27

**Issued to:** Hawke International A Division of Hubbell Limited  
Oxford St W  
Ashton-Under-Lyne, Lancashire OL7 0NA  
UNITED KINGDOM  
Attention: Roger Lomax

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** Donald Verbeem  
Donald Verbeem

## **PRODUCTS**

**CLASS - C441803 - CONDUIT FITTINGS-Fittings - For Hazardous Locations**

**CLASS - C441883 - CONDUIT FITTINGS-Fittings - For Hazardous Locations - Certified to US Standards**

**Ex db/Ex eb IIC Gb;**

**Ex tb IIIC Db;**

**Class I, Zone 1, AEx db IIC/AEx eb IIC Gb**

**Zone 21, AEx tb IIIC Db;**

**Class II Groups E,F, and G ; Class III**

**IP66**

- Type 487 Range of Stopping Plugs, with metric thread; M16 to M130, or North American Trade sizes ½” to 6” NPSM. Brass Stainless Steel and Aluminum

## **Notes:**

1. Stopping plugs without the machined groove and not provided with a seal are permitted for Class I, Zone 1, AEx/Ex d applications only and are not permissible for Class I, Zone 1, AEx/Ex e or any Class II or IP 66/67 applications.
2. The maximum operating temperature range of the stopping plug when fitted with a nitrile O-ring is -60°C to +80°C.



**Certificate:** 2700364  
**Project:** 70163398

**Master Contract:** 178267  
**Date Issued:** 2018-03-27

3. The maximum operating temperature range of the stopping plug when fitted with a silicone O-ring is -60°C to +160°C.
4. The maximum operating temperature range of the stopping plug without an O-ring fitted is -60°C to +200°C.
5. When the stopping plug is fitted in plain holes in increased safety or dust protected enclosures, the sealing face of the enclosure is to be smooth and the hole no larger than 0.7 mm above the major diameter of the male thread on the stopping plug. The stopping plug is to be secured with a locknut and optional locking washer.
6. When fitted in threaded holes, the sealing face of the enclosure is to be smooth, the threaded hole perpendicular to the wall of the enclosure and the thread medium fit.
7. End user must follow manufacturer's instruction sheets AI 411 (487series)

**Ex eb IIC Gb**  
**Ex tb IIIC Db;**  
**Class I, Zone 1, AEx eb IICGb**  
**Zone 21, AEx tb IIIC Db;**  
**IP66/67**

- **Type 375 Range of Stopping Plugs, with metric thread sizes; M16 to M75, Natural black plastic**

**Notes:**

1. When the stopping plug is fitted in plain holes in increased safety or dust protected enclosures, the sealing face of the enclosure is to be smooth and the hole no larger than 0.7 mm above the major diameter of the male thread on the stopping plug. The stopping plug is to be secured with a locknut and optional locking washer.
2. When fitted in threaded holes, the sealing face of the enclosure is to be smooth. The threaded hole perpendicular to the wall of the enclosure and the thread medium fit.
3. End user must follow manufacturer's instruction sheets and D2555(375 series)
4. For Series 375 Warning: M50, M63, and M75 stopping are a potential static ignition risk. Clean only with a damp cloth
5. End user must follow manufacturer's instruction sheets AI 410

**Ex eb IIC Gb;**  
**Ex tb IIIC Db;**  
**Class 1 Zone 1 AEx eb IIC Gb;**  
**Zone 21 AEx tb IIIC Db;**  
**IP66**

- **Type 383 Earth Adaptors** with metric thread; M20 to M75, or North American Trade sizes ½" to 3" NPT or NPSM. made from Brass, Nickel plated Brass or Stainless Steel

Operating Ambient range: -60°C to +80° C

Nomenclature

383-ab where  
a – male thread size  
b – female thread size

Notes:

1. End user must follow manufacturer's instruction sheets AI 413



**Certificate:** 2700364  
**Project:** 70163398

**Master Contract:** 178267  
**Date Issued:** 2018-03-27

- **Type 387 Stopping Plugs** with metric thread; M16 to M75, or North American Trade sizes ½” to 3” NPT or NPSM. made from Brass, Nickel plated Brass or Stainless Steel  
Operating Ambient range: -60°C to +160° C (when Silicon ring used) see Note 2

Nomenclature

387-a where  
a – male thread size

Notes:

- End user must follow manufacturer’s instruction sheets AI 378
  - Operating range is -60°C to +80°C when Nitrile ring is used
- **389 Increased safety Breather Drains** with M20 or M25 or North American ½” or ¾” NPT made from Brass, Nickel plated Brass or Stainless Steel  
Operating ambient range: -60°C to +160° C

Notes:

1. End user must follow manufacturer’s instruction sheets AI 408
  2. The Breather Drain Device must only be mounted on the bottom face of an enclosure.
- **390 Hex Stopping Plugs** with metric thread; M16 to M130, or North American Trade sizes ½” to 6” NPT or NPSM. made from Brass, Nickel plated Brass, Aluminum, or Stainless Steel  
Ambient range: -60°C to +160° C

TEMPERATURE RATINGS

-60°C to + 160°C  
with Red silicone (70 IRHD- less than 10% fillers) O-Ring fitted  
with Silicon O- Ring (EMI Reference S707)

-60°C to + 80°C  
With Nitrile O- Ring (BS2751 BA70)

Notes:

1. End user must follow manufacturer’s instruction sheets AI 412.
2. Temperature rating -60°C to +200°C when no O-ring fitted. IP 54 only when o-ring removed

**Class I, Zone 1, AEx db/Ex db IIC Gb;**

- **481 Male to Male & 482 Female to Female Unions** with metric thread; M16 to M75, or North American Trade sizes ½” to 3” NPT or NPSM threads made from Brass, Nickel plated Brass, Aluminum or Stainless Steel .

Operating ambient range: -60°C to + 80°C

Notes:

1. End user must follow manufacturer’s instruction sheets AI 407.



**Certificate:** 2700364  
**Project:** 70163398

**Master Contract:** 178267  
**Date Issued:** 2018-03-27

**Class I Zone 1 AEx db /Ex db IIC Gb**  
**Zone 21 AEx tb/Ex tb IIIC Db; IP66**

**Or**

**Class I Zone 1 AEx db/Ex db IIB + H2 Gb see Note 2 below;**  
**Zone 21 AEx tb/Ex tb IIIC Db; IP66**

- **489 Flameproof Breather Drain** with M20 or M25 or North American 1/2" or 3/4" NPT/NPSM made from Brass, Nickel plated Brass, Aluminum (see Note 4), or Stainless Steel  
Operating ambient range: -60°C to +60° C

Notes:

1. End user must follow manufacturer's instruction sheets AI 409
2. Only parts with SS sintered part may be IIC. Bronze sintered breather are IIB + H2 only
3. The Breather Drain Device must only be mounted on the bottom face of an enclosure maximum enclosure volume 2500 cubic cm.
4. Aluminum is Group II rated only

### **APPLICABLE REQUIREMENTS**

CAN/CSA C22.2 No 0 - 10	General requirements – Canadian electrical code, part II
CAN/CSA 22.2 No. 60079-0:11	Explosive atmospheres –General Requirements
CAN/CSA 22.2 No. 60079-1:16	Explosive atmospheres – Equipment protection by flameproof enclosures "d"
CAN/CSA 22.2 No. 60079-7:16	Explosive atmospheres –Equipment protection by increased safety "e"
CAN/CSA-C22.2 No. 60079-31:12	Explosive atmospheres –Equipment dust ignition protection by enclosure "t"
UL60079-0 6 <sup>th</sup> Ed	Explosive atmospheres –General Requirements
UL 60079-1 7 <sup>th</sup> Ed	Explosive atmospheres – Equipment protection by flameproof enclosures "d"
UL 60079-7 5 <sup>th</sup> Ed	Explosive atmospheres –Equipment protection by increased safety "e"
UL60079-31 2 <sup>nd</sup> Ed	Explosive atmospheres –Equipment dust ignition protection by enclosure "t"
IEC 60529	Degrees of Protection Provided by Enclosures (IP Code) – Edition 2.2

### **MARKINGS**

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.



**Certificate:** 2700364  
**Project:** 70163398

**Master Contract:** 178267  
**Date Issued:** 2018-03-27

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

**Nameplate adhesive label material approval information:**

Not Applicable

The following information shall be etched onto the external face of the product:

- The CSA Mark(s) that are to be applied to the product;
- Manufacturer's name or trade mark;
- Model number designation
- Thread size
- Hazardous Location designation
- cCSAus Monogram.

An assembly guide shall be supplied with each unit, containing the following minimum marking information:

- Manufacturer's name and address.
- Model number: As specified in the PRODUCTS section, above.
- Mounting and installation instructions, including relevant dimensions.

**Markings permitted in addition to ratings**

Note:

1. In accordance with UL60079-0 6th Edition, the following equivalent marking may be added.
2. In accordance with C22.2 N0 60079-0:11 mandatory additional marking is permitted
3. They shall not be used to replace the certification ratings

**Type 487 Range of Stopping Plugs**

- Class I Div. 1 and Div. 2 Groups A, B, C, D; Class II Div. 2 Groups E, F and G; Class III

**Type 375 Range of Stopping Plugs**

- Class I Div. 2 Groups A,B,C, D; Class II, Div. 2, Groups E, F and G; Class III



**Certificate:** 2700364  
**Project:** 70163398

**Master Contract:** 178267  
**Date Issued:** 2018-03-27

---

Type 383 Earth Adaptors

- Class I Div. 2, Groups A,B,C, and D; Class II Div. 2 Groups E,F,G; Class III

Type 387 Stopping Plugs

- Class I Div. 2, Groups A,B,C, and D; Class II Div. 2 Groups E,F,G; Class III

389 Increased safety Breather Drains

- Class I Div. 2, Groups A,B,C, and D; Class II Div. 2 Groups E,F,G; Class III

390 Hex Stopping Plugs

- Class I Div. 2, Groups A,B,C, and D; Class II Div. 2 Groups E,F,G; Class III

481 Male to Male & 482 Female to Female Unions

- Class I Div. 2 Groups A,B, C, and D

489 Flameproof Breather Drain

- Class I Div. 1 Groups A, B, C, D (aluminum only)

or

- Class I Div. 1 Groups A, B, C, D ; Class II Div. 1 Groups F,G; Class II Div. 2 Groups EFG and Class III

or

- Class I Div. 1 Groups B, C, D; Class II Div. 1 Groups F,G; Class II Div. 2 Groups EFG and Class III



## *Supplement to Certificate of Compliance*

**Certificate:** 2700364

**Master Contract:** 178267 (078713\_0\_000)

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
70163398	2018-03-27	Update report 2700364 to expand ratings of existing products to include Class and Div. as applicable and to add 375 series based on submitted information and testing.
70074131	2017-03-31	Update report 2700364 to add various fitting series to North American IEC listing based on submitted documentation
2700364	2014-02-12	Original Certification of Type 487 Range of Stopping Plugs, with metric threads only.